

GOVERNMENT OF NAGALAND
DIRECTORATE OF FIRE & EMERGENCY SERVICES
NAGALAND :: KOHIMA

NO.FHQ/MT-17/2019-20/313

Dated Kohima, the 20th March 2020

TO WHOM IT MAY CONCERN.

This is to certify that, inspection was carried out on 07.12.2019 in respect of Sainik School Punglwa, SO Medziphema, Peren District by Sub. Inspector Kezhalehou Sachu(i/o), where the institute have installed fire preventive appliances i.e 6 Nos. ABC Dry Powder (1 kg), 13 Nos. ABC Dry Powder(2 kg), 19 Nos. ABC Dry Powder(4 kg) & 4 Nos. ABC Dry Powder(6 kg) extinguishers in its premises for safety. However, they are advised to comply with the norms of National Building Code(NBC) 2016.



(T. Shifu Jamir)

DySP, FHQ

Nagaland, Kohima

Dy. Superintendent of Police (F&ES)
Directorate of Fire & Emergency Services
Kohima, Nagaland